

3.c.. Utilities & Infrastructure Factors – Fire Protection Water

Fire protection water: Provide information on pressure and flow at proposed site.

Fire Hydrants on this main flow 1500 gallons per minute at 90 psi residual pressure. This water main can supply the project demand of 330 gpm and 1250 gallons per minute fire flow with an average daily consumption of 110,140 gallons per day.